


Department of Power Engineering Mechanical Engineering University of Žilina

XIX. International Scientific Conference

THE APPLICATION OF EXPERIMENTAL AND NUMERICAL METHODS IN FLUID MECHANICS AND ENERGY 2014



The Application of Experimental and Numerical Methods in Fluid Mechanics and Energetics 2014

Proceedings of the International Conference

Measurement and calculation of state variables in the fluid flow, Modeling and simulation in fluid mechanics and energy, Optimization of flow parameters in the thermal and hydraulic machines and systems, Application of latest developments in the field of fluid mechanics and energy in technical practice, visualization of flow, Measurement of energy systems and systems, Special experimental methods in fluid mechanics and energy, Renewable energy, Current problems in the energy.

09.04. – 11.04.2014 Liptovský Ján, Slovakia

Edited by

Richard Lenhard; Katarína Kaduchová

Reviewers:

prof. RNDr. Milan MALCHO, PhD. prof. Ing. Jozef JANDAČKA, PhD. doc. Ing. Andrej KAPJOR, PhD. doc. Ing. Radovan NOSEK, PhD. doc. Ing. Štefan PAPUČÍK, PhD.

The texts of the papers in this volume were set individually by the authors. Only minor corrections to the text may have been carried out by the publisher. Any options, findings and conclusions or recommendations expressed in this book are those of the individual authors on their own responsibility.

Faculty of Mechanical Engineering University of Žilina

ISBN 978-80-554-0855-2

Guarantors of the conference:

prof. Ing. Jozef Jandačka, PhD., ŽU Žilina, SR prof. RNDr. Milan Malcho, PhD., ŽU Žilina, SR

Sciences Committee:

prof. Dr. hab. inž. Ryszard A. Bialecki, University of Technology, Gliwice, PL

prof. Ing. Mária Čarnogurská, CSc., TU Košice, SR

doc. Ing. Jozef Černecký, CSc., TU Zvolen, SR

prof. Ing. Ladislav Dzurenda, PhD., TU Zvolen, SR

prof. Ing. Peter Horbaj, PhD., TU Košice, SR

prof. Ing. Jozef Jandačka, PhD., ŽU Žilina, SR

RNDr. Pavel Jonáš, DrSc., UT AVČR Praha, CZ

prof. Ing. František Kavička, CSc., VUT Brno, CZ

doc. Ing. Branislav Knížat, CSc., STU Bratislava, SR

prof. Ing. Václav Kopecký, CSc., TU Liberec, CZ

prof. dr. sc. Ladislav Lazič, University of Zagreb, Zagreb Croatia

prof. RNDr. Milan Malcho, PhD., ŽU Žilina, SR

doc. dr. Ing. Tadeáš Ochodek, VŠB - TU Ostrava, CZ

doc. Ing. Róbert Olšiak, PhD., STU Bratislava, SR

prof. Ing. Jaromír Příhoda, CSc., UT AVČR Praha, CZ

prof. Ing. Miroslav Příhoda, CSc., VŠB - TU Ostrava, CZ

doc. Ing. Josef Soukup, CSc., UJEP Ústi nad Labem, CZ

prof. Andrzej Szlek, PhD., DSc., University of Technology, Gliwice, PL

prof. Ing. Pavel Šafařík, CSc., ČVUT Praha, CZ

doc. Ing. Peter Tauš, PhD., TU Košice, SR

doc. Ing. František Urban, PhD., STU Bratislava, SR

prof. Ing. Augustín Varga, CSc., TU Košice, SR

Steering Committee:

Ing. Richard Lenhard, PhD., ŽU Žilina, SR

Ing. Slavka Jelušová, ŽU Žilina, SR

OBSAH

Solar Ventilation and Tempering
Karel Adámek, Miloš Pavlů, Milan Bandouch
CFD Modeling of Moist Air Condensation Using Standard Commercial Software 7 Jan Barák, Karel Fraňa
Ambient temperature on the electrical strength of the heat pipe
Power losses and the efficiency of industrially used gearboxes
Micro-cogeneration units based on Stirling engine for heating and their real operation
Jaroslav Čierny, Marek Patsch
Emission of nanoparticles during combustion of waste biomass in fireplace25
Vendula Drastichová, Kamil Krpec, Jiří Horák, František Hopan, Petr Kubesa, Lubomír Martiník, Jan Koloničný, Tadeáš Ochodek, Michal Holubčík
Verifying of boundary conditions for heat exchanger design by burning pellets31
Peter Ďurčanský, Jozef Jandačka, Andrej Kapjor
Solution for the flow of the direct blade cascades35
David Fenderl, Jan Uher, Robert Kalista
Structural view to natural gas hydrates
Viktor Foltin, Ján Rajzinger, František Ridzoň
Relation between chemical composition and structure of biomass ash45
Michal Holubčík, Jozef Jandačka
Differences between biomass pellets made in domestic conditions and in manufactory production
Michal Holubčík, Ewa Jachniak, Helena Smatanová
Influence of Interstage Seal Flooding on the Aerodynamic Parameters of Two-Stage Experimental Trubine with Drum-Type Rotor
Michal Hoznedl, Ladislav Tajč, Lukáš Bednář
Influence of condenser type of the loop thermosyphon on its cooling effect57
Peter Hrabovský, Patrik Nemec, Milan Malcho
Analysis of the heat transfer from "n" horizontal pipes one above another at natural convection using the known criterial equations and CFD methods
Andrej Kapjor, Jozef Hužvár, Branislav Ftorek, Helena Smatanova

POD Decomposition of CFD Data of Flow Controlled Flow Over Hump65 Tomáš Hyhlík
Effect of various fuel quantity on particulate matter formation
Biomass Gasification for Liquid Fuel Production
TiO2 based nanostructured materials studied by thermogravimetric methods77 Zuzana Jankovská, Lenka Matějová, Jiří Horák, Jana Kukutschová, Jozef Jandačka, Michal Holubčík
Experimental research of gas heat pump air - water in cooling mode
The methodic for study of smart surfaces using PIV technique
Measuring performance parameters gravitational heat pipes depending on the amount of working fluid in vertical position
Marián Jobb, Patrik Nemec, Ľuboš Kosa, Milan Malcho
Experimental apparatus for measurement of the adsorption tetrahydrothiophene (THT) in soils. Calibration, method of measurement and processing the data95
M. Juriga, D. Bobok, Š. Gužela, K. Jelemenský, R. Kubinec, J. Rajzinger, V. Foltín Parameters of Central Boiler Depending the Amount of Combustion Air101 Katarína Kaduchová, Jozef Jandačka, Richard Lenhard, Jan Koloničný, Jiří Horák
Thermovision and CFD method as the process of heat transfer optimalization 105 Andrej Kapjor, Tomas Gressak, Jozef Huzvar, Martin Vantuch
Mathematical model of heat transport through gravity assisted heat pipe109 Martin Kasanický, Richard Lenhard, Milan Malcho
Influence of biomass blending on pyrolysis process using TGA-FTIR technique 113 Jakub Bibrzycki, Anna Katelbach-Woźniak, Andrzej Szlęk
Behavior of flowing air through a pipeline with installed orifice plate117 Roman Kiš, Milan Malcho, Martina Janovcová
The impact of contaminated biomass for the formation of emission in the combustion process of producer gas in the cogeneration unite
Kočanová Slávka, Lukáč Ladislav, Széplaky Dávid, Lazić Ladislav
Thermal performance of closed loop pulsating heat pipe with different types of working fluid
Zuzana Kolková, Milan Malcho

Working position to influence thermal performance capillary heat pipe129
Ľuboš Kosa, Patrik Nemec, Marián Jobb,Milan Malcho
Lump wood combustion process
Kubesa Petr, Horák Jiří, Krpec Kamil, Hopan František, Drastichová Vendula, Martiník Lubomír, Koloničný Jan, Ochodek Tadeáš, Malcho Milan
Affect Volumes of Heat Pipes to Transport Heat143
Richard Lenhard, Katarína Kaduchová, Štefan Papučík
Experimental Technique for Setup of Supersonic Inlet Flow in a Profile Blade Cascade
M.Luxa, B. Rudas, J. Synáč, P.Šafařík, D.Šimurda
Dependence of performance on the position of the gravitational heat pipe153
Mančiková Veronika, Čaja Alexander, Malcho Milan
Structural design of Stirling engine with free pistons15
Jozef Matusov, Stanislav Gavlas, Milan Malcho
The design of heat exchanger in small pellet boiler for phytomass combustion with help of CFD
Jozef Mičieta, Richard Lenhard, Jozef Jandačka
Cotribution to the Design of a Hydrostatic Forming tool165
Ján Moravec
Biomass Gasification for Liquid Fuel Production169
Jan Najser, Václav Peer, Martin Vantúch
Methods for observations of the cavitation erosion on solid materials surfaces 173
Róbert Olšiak, Branislav Knížat, Marek Mlkvik, Juraj Krajanec
Boiling heat transfer on meshed surfaces of different aperture
Analysis of closed hot air engine cycle in the modeling environment MatLab - Simulink
Pavol Oršanský, Branislav Ftorek, Peter Ďurčanský
Micro-cogeneration Based on Fuel Cell18
Marek Patsch, Jaroslav Čierny
Calculation of Steam-Water Injector Properties
Modifiers of the Ash Properties189
Václav Peer, Jan Najser, Peter Pilát
The problem of cracking cores during casting piston in moulds I

Heat transfer to the adsorbent in solar adsorption cooling device199
Peter Pilát , Marek Patsch , Štefan Papučík , Martin Vantúch
Comparison of various laminar/turbulent transition models203
Jaromír Příhoda, Petr Straka, Jiří Fürst, Lukáš Popelka
Comparative study of selected thermodynamic derivative properties of methane for isenthalpic and isothermal throttling and isentropic processes207
Ján Rajzinger, František Ridzoň, Ján Kizek, Viktor Foltin, Branislav Knížat
A Seven-Hole Pneumatic Probe213
Sedlák Kamil, Hoznedl Michal, Tajč Ladislav
Verification of turbulence model217
Blanka Skočilasová, Jan Skočilas
Aerosols and the Methods of Determining the Characteristics of Nanoparticles 221
Mária Skřínská, Jiří Horák, Pavel Danihelka, Kamil Krpec, František Hopan, Zdeňka Kaličáková, Petr Kubesa, Lubomír Martiník, Vendula Drastichová, Jan Koloničný, Tadeáš Ochodek, Jozef Jandačka
Impact of a porosity and a permeability of wick in a vertical LHP to remove waste heat from the electronic equipment229
Martin Smitka, Patrik Nemec, Milan Malcho
Influence of Inlet Nozzle on Secondary Flow in Axial Stator Blade Cascade233
Petr Straka, Jan Šimák, Jaroslav Pelant
Modification of the Fleu Gas Path with regard to particulate matter reduction 237
Katarína Sulovcová, Jozef Jandačka, Radovan Nosek
Influence of gas temperature on temperature field in the area of transit gas- pipeline
Dávid Széplaky, Augustín Varga, Ján Rajzinger
Range of Valid Arguments for Data Reduction Method in the Steam Flow Fields 245
P. Šafařík, A. Nový, M. Hajšman, D. Jícha
Testing of the Steam – Water Heat Exchanger Characteristics with the Small Diameter Tubes
F. Urban, M. Kubín , Ľ. Kučák
Sensitivity analysis of the thermometer of the fuel assembly physical model253
F. Urban, Ľ. Kučák, J. Bereznai, Z. Závodný, P. Muškát
Dynamics of Reattachment of the Flow behind Backward-Facing Step in a Narrow Channel
Václav Uruba

The Influence of the Radial Diffuser Geometry on the Position of Best Efficiency Point of the Multistage Pump261
Michal Varchola, Peter Hlbočan
Theoretical models on prediction of thermal conductivity of nanofluids267
Shalimba Veikko, Skočilasová Blanka
Influence of sealing steam on the flows in turbine stages
Comparison of Twin-fluid Atomizers Using a Phase Doppler Analyser275 Matouš Zaremba, Milan Malý, Jan Jedelský, Miroslav Jícha
The Measurement of Abrasive Particles Velocities in the Process of Abrasive Water Jet Generation
Michal Zelenak, Josef Foldyna, Zdenek Riha
Molten Salt Reactors Cooling by "Gas-lift"
Pavel Zitek, Vaclav Valenta, Marek Klimko



AEaNMiFMaE 2014, 09-11 April 2014

University of Žilina, Department of Power Engineering, Žilina, Slovak Republic



Parameters of Central Boiler Depending the Amount of Combustion Air

Katarína Kaduchová*, Jozef Jandačka*, Richard Lenhard*, Jan Koloničný**, Jiří Horák***

*University of Žilina, Faculty of Mechanical Engineering, Department of Power Engineering, Univerzitna 1, 010 26 Žilina, Slovakia, {katarina.kaduchova, jozef.iandacka.richard.lenhard}@fstroi.uniza.sk

ARTICLE INFO

Article history: Received 28 February 2014 Accepted 08 March 2014

Published 09 April 2014 Keywords:

Pellet boiler, biomass, experimental measurements

ABSTRACT

The production of solid pollutants is affected by several influences. Moreover, the amount of combustion air and its redistribution to primary and secondary combustion air. The experimental device, on which has been examined the amount of the combustion air on the production of the solid pollutants, methods of measurement, measurement's results and analysis of the results obtained will be described in the article.

Nomenclature

p_k chimney draft, Pa P boiler output, kW

t output of the boiler water, °C

tr inlet water to the boiler, °C

T temperature, °C

T_c flue gas temperature, °C

T_o the ambient temperature, °C

v rate of supply air, m/s

Q flow rate, m³/h

Q_{vh} heat transfer fluid flow rate, m³/h

1. Introduction

Wood is the many millions of years for man one of the most important fuel sources. Essential for its use is that energy can be recovered in a sustainable manner. The annual increase in global timber is estimated at 12.5 billion cubic meters with an energy content of 182 EJ, which is about 1.3 times the annual global coal consumption. Average consumption of wood for all purposes is about 3.4 billion cubic meters per year (the equivalent of 40 EJ per year). It follows that in the world there is considerable potential for using wood for energy purposes. The great advantage of wood is that in a good save to keep their energy content, let alone within the first 2 to 3 years of relative increases. It is a fact that in this dry period. This fact is important because moisture in the wood is released to the boilers at the expense of heating value. At the same time the burning of wet wood decreases the combustion temperature, leading to incorrect oxidized all the combustible ingredients, there is smoke, choking smoke pipes and to reduce boiler life. The main sources of wood biomass (biomass) as forest management, where part of the excavated material is unsuitable for use in the woodworking industry. Another source of the timber industry, which in the manufacturing process produces wood waste suitable for energy use. Prospective source of the wood material, which can produce a less productive agricultural soils, respectively. Other non-forest land cultivation so. fast-growing trees. Tree material consists of wood, bark and green materials, i.e. branches and needles of conifers. Coniferous trees consist of 70 to 80 % wood, 10 to 15 % bark and 10 to 15 % of green matter. Deciduous trees shall consist of 60 to 75 % wood, 10 to 20 % bark and 15 to 20 % of green matter.

2. Experimental measurements

The as the heat source was used pellet boiler firm. Lokca with a rated output of 18 kW with the type designation Lokca 18 automatic savings that have been involved with measuring elements according to Fig. 1.

Pellet boiler Fig. 1 is designed for burning pellets and coal type nut. Measurement of the rated power is held in different settings the intake air mass flow to the combustion burner for pellets.

Each rated capacity is recorded and evaluated separately, and each measurement was used identically fuel. The amount of injected combustion air be regulated by the control system via the boiler control fan speed in the range 10 % - 100 %. Set the controls for the supply of wood pellets has been set

^{*}VŠB, Technical University Ostrava, Faculty of safety engineering, 17. listopadu 15/2172, 708 33 Ostrava Poruba, jan.kolonicny@vsb.cz

^{***} VŠB, Technical University Ostava, Energy research center, 17. listopadu 15/2172, 708 33 Ostava Poruba, jirka.horak@vsb.cz

for each measurement to the same value, i.e. fuel delivery is the same for all measurements. Performance measured on pellet boilers is measured by the indirect method, according to the measurement of small heat sources. Schematic diagram of the boiler is measured by the Fig. 2.

To evaluate the quality of combustion flue gas composition was measured by gas analyzer ABB AO 2020. The unit focuses on the analysis of gaseous emissions. Taking the single-gas, stainless steel probe. The input samples into the sampling line is heated in a protective housing ceramic filter captures impurities. The sample continues the sampling line to the measuring system. Management is heated in order to prevent condensation of sample. The measured gas is fed into the refrigerator. It is guided through the filters and valves transported to the analyzer unit. Analyzer ABB AO 2020 is folded according to the requirements and nature of the measurement. If measurements of emissions from burning wood in fireplaces stoves were used measuring devices 26 and Uras MAGNOS 206th To accurately analyze the performance and emission parameters of a single set of incoming air to the pellet burner is always measured about 120 min.

During the combustion process one batch of fuel is recorded following values: the ambient temperature T_o [°C]; chimney draft p_k [Pa]; flue gas temperature T_c [°C]; output of the boiler water t [°C]; inlet water to the boiler t_r [°C]; heat transfer fluid flow rate Q_{vh} [$m^3.h^{-1}$]; air supply rate to the burner [$m.s^{-1}$]; temperature of the injected air to the burner [°C]; the composition of gases: oxygen O_2 [%], carbon dioxide CO_2 [%], carbon monoxide CO_2 [%], carbon monoxide CO_2 [ppm], nitric oxide CO_2 [ppm], sulfur dioxide CO_2 [ppm], solid organic carbon CO_2 [mg.m⁻³].





Fig. 1 experimental measurements of pellet boiler.




Fig. 2 schematic diagram of the boiler.



AEaNMiFMaE 2014, 09-11 April 2014

University of Žilina, Department of Power Engineering, Žilina, Slovak Republic



3. Analysis results

During the measurements were monitored and recorded values of CO, CO_2 , SO_2 , NO_x , O_2 , TOC in the flue gas and then to evaluate the performance and efficiency of test equipment, each set of air injected into the burner. In addition, emissions were measured and the parameters: temperature of the flue, chimney draft and ambient temperature. Were measured, as mentioned above, each set separately injected air into a pellet burner to record data using the panel to a computer in the twenty-second intervals. The data is post edited by Microsoft Office software in a minute diameters of which made the overall average for each single measurement of the rated power. Finally, did the overall mean of the measured values of all benefits. The resulting readings are brought to the bar graphs. The measured results is interesting to know whether the results of emission and performance parameters. The measured parameters of hot water boiler, depending on the amount of combustion is seen as affecting the amount of combustion air to their mean values.

The insufficient amount of combustion air inlet to produce significantly higher concentrations of CO Fig. 3, OGC Fig. 4. However, the supply of large quantities of combustion air is reflected in the increased production of CO Fig. 3, respectively. OGC Fig. 4. Increasing the concentration of CO respectively. OGC has a major impact on the heat capacity Fig. 5, respectively. Efficiency of the heat source Fig. 6. To change the amount of combustion air to substantially change the concentration of NO_x , unless the least amount of combustion air.




Fig. 3 the average value of production of CO, depending on the mass flow combustion air.




Fig. 4 the average value of production OGC based on mass flow combustion air.




Fig. 5 the average values of heat output depending on the mass flow combustion air.




Fig. 6 the average values of heat efficiency on the mass flow combustion air.

Acknowledgement

This paper was prepared within the project "Rozvoj spolupráce medzi VEC a KET so zameraním na odborný rast doktorandov a výskumných pracovníkov" ITMS 22410320106.

References

- [1] Buczyński, R., Weber, R., Szlek, A., Nosek, R. Time-dependent combustion of solid fuels in a fixed-bed: measurements and mathematical modeling. Energy & fuels, 2012.
- [2] Nosek, R., Jurkechová, J., Papučík, Š., Jandačka, J. *Influence of fuel supply to in small capacity boiler on efficiency and pollutant emissions*. Experimental fluid mechanics, 2010.
- [3] Chabiński, M., Szlek, A. *Porównanie wybranych algorytmów sterovania kotłami węglowymi malej mocy*. Nowoczesne ciepłownictwo, 2011.
- [4] Branc, M., Bojko, M. A definition of the mathematical model of combustion process in the stove. Journal of Applied Science in the Thermodynamics and Fluid Mechanics, 2009.
- [5] Lábaj, J., Kapjor, A., Papučík, Š. Alternatívne palivá pre energetiku a dopravu. Žilina, 2010.
- [6] Gavlas, S., Matušov, J., Malcho, M. *Analýza veľkosti a hustoty tuhých znečisťujúcich látok zo spalín produkovaných pri tavbe sekundárneho hliníka*. 32. stretnutie katedier mechaniky tekutín a termomechaniky. 2013.
- [7] Nosek, R., Holubčík, M. Measurement of particulate matter during the combustion of phytomass in small heat sources. Power control and optimization.

The Application of Experimental and Numerical Methods in Fluid Mechanics and Energy 2014

XIX. International Scientific Conference

Edited by: Richard Lenhard, Katarína Kaduchová

Published by: University of Žilina

Edition: First

Printed by: EDIS – Žilina University Publisher

Impresion: 90

ISBN 978-80-554-0855-2